



Gauge Calibration Service Checklist

Please take the following steps to prepare your gauge for calibration services:

- ☐ Open all valves and drain water from gauge
- ☐ Remove pressure hoses and set aside
(Don't ship with unit – *Except Watts TK-9A*)
- ☐ Leave all valves in the open position
- ☐ Place in shipping box (With customer supplied packing to prevent damage)
- ☐ Tape box closed
- ☐ Write sales order # on the outside of the box
- ☐ Attach the included UPS shipping tag
(Do not cover up sales order #)
- ☐ Drop off at any authorized UPS shipping point

NOTE: Shipping label is provided.

CONTACT US WITH ANY QUESTIONS. WE ARE HAPPY TO HELP!

CALL US: 800.336.6530 **EMAIL US:** Calibrations@BackflowPreventer.com

VISIT WEBSITE: BackflowPreventer.com/CalibrationServices