**Double Check Detector Assemblies** 

Sizes: 21/2" - 10" (65 - 250mm)

- Installation
- Service
- Repair Kits
- Maintenance

For field testing procedure, send for IS-TK-DL, IS-TK-9A IS-TK-99E and IS-TK-99D.

For other repair kits and service parts, send for PL-RP-RPD.

For technical assistance, contact your local Watts representative.









**757 OSY** 

#### **CALIFORNIA PROPOSITION 65 WARNING**

**WARNING:** This product contains chemicals known to the State of California to cause cancer and birth defects or other reproductive harm. (California law requires this warning to be given to customers in the State of California.)

For more information: www.watts.com/prop65

**IMPORTANT:** Inquire with governing authorities for local installation requirements.

Note: For Australia and New Zealand: Pipeline strainers should be installed between the upstream shutoff valve and the inlet of the backflow preventer.

It's important that this assembly be tested periodically in compliance with local codes, but at least once per year or more as service conditions warrant. If installed on a fire sprinkler system, all mechanical checks, such as alarm checks and backflow preventers, should be flow tested and inspected internally in accordance with NFPA 13 and NFPA 25.

Limited Warranty: Watts Regulator Co. (the "Company") warrants each product to be free from defects in material and workmanship under normal usage for a period of one year from the date of original shipment. In the event of such defects within the warranty period, the Company will, at its option, replace or recondition the product without charge

THE WARRANTY SET FORTH HEREIN IS GIVEN EXPRESSLY AND IS THE ONLY WARRANTY GIVEN BY THE COMPANY WITH RESPECT TO THE PRODUCT. THE COMPANY MAKES NO OTHER WARRANTIES, EXPRESS OR IMPLIED. THE COMPANY HEREBY SPECIFICALLY DISCLAIMS ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, INCLUDING BUT NOT LIMITED TO THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR

The remedy described in the first paragraph of this warranty shall constitute the sole and exclusive remedy for breach of warranty, and the Company shall not be responsible for any incidental, special or consequential damages, including without limitation, lost profits or the cost of repairing or replacing other property which is damaged if this product does not work properly, other costs resulting from labor charges, delays, vandalism, negligence, fouling caused by foreign material, damage from adverse water conditions, chemical, or any other circumstances over which the Company has no control. This warranty shall be invalidated by any abuse, misuse, misapplication, improper installation or improper maintenance or alteration of the product.

Some States do not allow limitations on how long an implied warranty lasts, and some States do not allow the exclusion or limitation of incidental or consequential damages. Therefore the above limitations may not apply to you. This Limited Warranty gives you specific legal rights, and you may have other rights that vary from State to State. You should consult appli-cable state laws to determine your rights. SO FAR AS IS CONSISTENT WITH APPLICABLE STATE LAW, ANY IMPLIED WARRANTIES THAT MAY NOT BE DISCLAIMED, INCLUDING THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, ARE LIMITED IN DURATION TO ONE YEAR FROM THE DATE OF ORIGINAL SHIPMENT.




## **Basic Installation Instructions**

Guidelines

Most field problems occur because dirt and debris present in the system at the time of installation becomes trapped in the #1 check. The system should be flushed before the backflow valve is installed. If the system is not flushed until after the backflow valve is installed, remove both check modules from the valve and open the inlet shutoff to allow water to flow for a sufficient time to flush debris from the water line. If debris in the water system continues to cause fouling, a strainer can be installed upstream of the backflow assembly.

Watts models 757 and 757DCDA/LF 757DCDA may be installed in either horizontal or vertical position as long as the backflow assembly is installed in accordance with the direction of the flow arrow on the assembly and the local water authority approves the installation. The assembly should be installed with adequate clearance around the valve to allow for inspection. testing and servicing. 12" should be the minimum clearance between the lower portion of the assembly and the floor or

Note: Assembly body should not be painted.



## Maintenance Instructions 21/2" - 6" (65 - 150mm)







Figure A

Figure B

Figure C







Figure D

Figure E

Figure F

Prior to servicing any Watts valve, it is mandatory to shut down the water system by closing both the inlet and outlet shutoff valves. After shutoff valves are closed, open test cock #2, #3 and #4 to relieve pressure within the backflow assembly.

- 1. After #3 test cock has been opened to relieve pressure, remove #3 test cock from housing. (Figure A)
- 2. Insert a #3 screwdriver through the hole on the top of the cover sleeve and using both hands rotate the cover sleeve approximately 1/4-turn clockwise and 1/4-turn counter-clockwise to break the sleeve O-ring seals. Using the screwdriver, slowly slide the cover sleeve to the downstream side of the housing. (Figure B)
- 3. Remove the stainless steel check retainer from the housing. (Figure B)
- 4. Remove the #1 check module (Figure C) by inserting two flat blade screwdrivers into the slots on either side of the check module and gently pry the check module toward the open zone.

- 5. Remove #2 check module with the same instructions as in #4 above. For servicing 6" (150mm) checks see 8" - 10" (200 - 250mm) instructions on p. 3.
- 6. To clean or inspect either check module, insert a #3 screwdriver through the downstream side of the check module as shown in Figure D and E. When the screwdriver is in place, remove the E-clip (Figure F) and pin connecting the structural members and the check clapper will open with no tension.
- 7. Thoroughly clean the seating area. The sealing disk may be removed, if necessary, by removing the screws connecting the keeper plate to the clapper. The sealing disc may be reversed and reinstalled if the elastomer is cut or damaged.
- 8. Wash check module and O-ring and inspect for any damage. If damaged, reinstall new parts.
- 9. After thorough cleaning, lubricate O-ring w/FDA approved lubricant, replace pin and E-clip in structural members, remove screw driver and reinstall check modules and assemble housing in reverse order of these instructions.

## Maintenance Instructions 8" - 10" (200 - 250mm)

#### Material/Tool Requirements:

- #3 Phillips screwdriver or <sup>5</sup>/<sub>16</sub>" diameter rod, length sufficient to span diameter of check, see Figures A and B.
- 1/2" 13 x 5" fully threaded hex bolt (Service bolt).
- 3/4" open end or socket wrench.

## Figure A Service Hole

system

#### Instructions:

Prior to servicing any Watts valve, it is mandatory to shut down the water by closing both the inlet and outlet shutoff valves. After shutoff valves are closed, open test cock #2, #3 & #4 to relieve pressure within the backflow assembly.

- 1. After #3 test cock has been opened to relieve pressure, remove #3 test cock from housing.

  When repairing an 8" or 10" (200 250mm) device, remove both Victaulic couplers from body. Slide the downstream Victaulic coupler gasket to the downstream side of the housing. The upstream Victaulic coupler gasket stays in place.
- 2. Remove check/s to be maintenanced.

- 3. Locate the service hole and thread in the service bolt by hand until it contacts the linkage. (Figure A)
- Continue to thread in service bolt with the wrench until the service hole in the linkage is aligned with the service notches on the spring arbors. (Figure A)
- Insert the Phillips screwdriver through the arbors and service hole of the linkage making sure that the tip of the screwdriver extends past the ends of the arbors by a minimum of 1/4" (6mm). (Figure B)
- Back out the service bolt until load is transferred to the screwdriver. Continue to back out the service bolt until sufficient clearance is achieved to remove the complete spring mechanism.
- 7.To disconnect linkage, remove retaining clip and pin (store in a safe location for reinstallation).
- 8. To remove spring mechanism, grasp the screwdriver at the center and pull complete assembly straight out and store in a safe place.
- 9. Reinstall in reverse.

**WARNING** – While the spring mechanism is removed for check servicing; never pull the screwdriver out or off the support notches on the arbors. Doing so may cause bodily injuries.

## Test Procedures Double Check Valve Assemblies

#### Test Check Valve No.1

- Step 1: Ensure shutoff #1 is open, shutoff #2 is closed.
- Step 2: Connect high side hose to test cock #3, low side to test cock #2 and open both test cock #2 and test cock #3.
- Step 3: Open valve C, then open A to bleed air from the high side. close valve a, then open B to bleed low side. Close valve B.
- Step 4: Connect vent hose loosely to test cock#1. Open valve A to vent air from vent hose, Tighten vent hose at test cock #1, open test cock #1.
- Step 5: Close shutoff #1. Slowly loosen hose at test cock #2 until differential gauge rises to 2psi and retighten hose. If the differential reading does not decrease, record check valves as "tight".

### Test for Leaky No. 2 shutoff


- Step 1: Connect the high side to test cock #1, low side to test cock #4. Open test cock #1 and test cock #4. Close shutoffs #1 and #2.
- Step 2: Close valve C. Open valve A, then open valve B ½ turn, loosen hose at test cock #4 to remove air. Retighten hose.
- Step 3: If the differential gauge rises above 0, there is excessive leakage at shutoff #2 and it must be replaced to test the assembly.

### Test Check Valve No. 2


- Step 1: Move the high side hose to test cock #4, low side to test cock #3 and open both test cock #3 and test cock #4. Remove vent hose from test cock #1, open shutoff #1.
- Step 2: Open valve C, then open valve A to bleed air from the high side. Close valve A, then open valve B to bleed low side. Close valve B.
- Step 3: Connect vent hose loosely to test cock #1. Open valve A to vent air from the vent hose. Tighten vent hose at test cock #1, open test cock #1.
- Step 4: Close shutoff #1, then slowly loosen hose at test cock #3 until differential gauge rises to 2psi and retighten hose. If the differential reading does not decrease, record check as tight. Remove all hoses and restore valve to original working condition.

**Note:** The assembly will fail both the first and second check valve tests above, if shutoff #2 leaks excessively. To test for a leaky #2 shutoff, use the following procedure.

#### Ball Type Test Valves



# Series 757, 757N, 757DCDA, LF757DCDA 757NDCDA, LF757NDCDA Repair Kits



Second	Check	Module
--------	-------	--------

ORDERING NO.	SIZE		DISC	MODEL	
	in.	mm			
1st Check Kit	s				
7018128	21/2 - 4	65-100	Red Silicone	RK 757/757DCDA CK1	
7018131	6	150	Red Silicone	RK 757/757DCDA CK1	
7018134	8	200	Red Silicone	RK 757/757DCDA CK1	
0899200	10	250	Red Silicone	RK 757/757DCDA CK1	

**Kit consists of:** First check module, Check module 0-ring and Disc elastomer

2nd	Check	Kits

7018130	21/2 - 4	65-100	Red Silicone	RK 757/757DCDA CK2
7018133	6	150	Red Silicone	RK 757/757DCDA CK2
0899206	8	200	Red Silicone	RK 757/757DCDA CK2
0899201	10	250	Red Silicone	RK 757/757DCDA CK2

Kit consists of: Second check module, Check module 0-ring and Disc elastomer

ORDERING NO.	The same	IZE	DISC	MODEL	
	in.	mm			
1st or 2nd Ch	eck Rub	ber Parts	Kits		
0899202	21/2 - 4	65-100	Red Silicone	RK 757/757DCDA RC4	
0899203	6	150	Red Silicone	RK 757/757DCDA RC4	
0899204	8	200	Red Silicone	RK 757/757DCDA RC4	
0899205	10	250	Red Silicone	RK 757/757DCDA RC4	

Kit consists of: Check module O-ring, Disc elastomer and E-clip

#### **Check Sleeve Cover Kits**

Ī	0899211	21/2 - 4	65-100		RK 757/757DCDA C
	0899212	6	150	_	RK 757/757DCDA C
	0899213	8	200	-	RK 757/757DCDA C
	0899214	10	250		RK 757/757DCDA C

Kit consists of: Closure sleeve, Sleeve O-ring and Gasket



ISO 9001-2008

USA: 815 Chestnut St., No. Andover, MA 01845-6098; www.watts.com Canada: 5435 North Service Rd., Burlington, ONT. L7L 5H7; www.wattscanada.ca